



**THE CORPORATION OF THE TOWN OF  
ATIKOKAN**

**Windows and Doors replacement**

**Pioneer Centre  
(Seniors Active Living Centre)**

**223 Burns Street**

**Request for Proposal**

**\*\*Closing date Jan 30 2025 2:00 p.m.\*\***

**Addendum #2**

Question: What type of windows to be installed.

Answer: Fixed, A340 low E argon filled, double pane